



- Legend**
- Site boundary
  - Flow Control Manhole
  - Rainwater Pipe
  - Existing Surface Water Manhole
  - Proposed Surface Water Manhole
  - Carrier Drain
  - Existing Surface Water Drainage Pipe
  - Proposed Surface Water
  - Below Ground Cellular Storage Tank (Lined)
  - Surface water ponding (for storm events in excess of the 1 in 30 year event +CC, avg. 150mm)
  - Main Building

Light-liquid separators to be installed as required as part of new SW drainage network.



Drawn at A3  
1:1,200

**Note**  
Please refer to Figure 08 of Flood Risk Assessment 'Surface Water Drainage - Indicative Long Section' for Long Section A-A.

Client  
**Ford EfW Ltd, Grundon & Viridor**

Project Title  
**Ford Energy Recovery Facility and Waste Sorting and Transfer Facility, Ford Circular Technology Park**

Project Number  
**1620007830**

Figure Title  
**Outline Surface Water Drainage Strategy**



Tel: 023 8081 7500 southampton@ramboll.co.uk  
Fax: 023 8081 7600 www.ramboll.co.uk

Date June 2020	Prepared By CS/BH
-------------------	----------------------

Drawing No. 1620007830-RAM-00-00-DR-E-00001	Revision P01
--	-----------------

